

The Principal,
International Delhi Public School,
Nagbal Imamsahib Shopian.

No: DFES/FP/9/2023-04/CC-7079422-6040


Dated. 19 : 03:2024.

Sub: - Fire & life safety measures/ guidelines in favour of International Delhi Public School situated at Nagbal Imamsahib Shopian & provisional clearance thereof.

Ref:- Your online application submitted dated, 12-03-2024 Tracking Id No. F1026-5827835.

The inspection of above said school was got carried out by the Inspecting officer of this department and found that the management has installed 07 units ABC type 06 kg, 04 units water type 09 liters capacity and Hose reel in each floor connected with terrace tank 5000 liters fitted with pump first aid fire extinguishers in the school premises. However the site is about 07 Km away from Fire & Emergency Station Zainapora and is accessible for fire tenders. Since the school is already functioning in triple storeyed building, as such the management can proceed ahead for operation provisionally subject to strictly adopt the following fire safety measures/guidelines in letter and spirit forthwith for the safety of students studying there:-

- 1 (One) 01 No. each of CO₂ type fire extinguisher of 4.5 kg capacity shall be provided near main electric switch board panel & in computer lab, in addition to already existing fire extinguisher.
- 2 Existing hose reel shall be connected with dedicated terrace water tank 10,000 liters capacity.
- 3 Wooden components of the structure especially in attic portion shall be given fire retardant treatment of at least two hours rating.
- 4 All exits/entrances shall be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency. The corridor of the building shall not be used for any kind of storage.
- 5 No Hazardous material shall be kept inside of the school premises (especially LPG cylinder, Petrol, Diesel and Central Heating System etc.) Any deviation found in this regard, this fire safety provisional certificate/guidelines issued will be treated automatically withdrawn/cancelled.
- 6 The Management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
- 7 Class/Halls have a capacity of more than 45 students shall have two exits. Fire/Evacuation drill should be conducted regularly. Employees of the school shall be trained for maintenance & use of Fire Fighting facilities.
- 8 The department can make a surprise visit to your school at any time. During the visit if the fire fighting system (i.e. existing as well as proposed) found defunct and deviation, this fire safety provisional certificate/guidelines issued will be treated automatically withdrawn/cancelled.
- 9 At present school is functional in triple storeyed CGI sheet roofed building over iron truss having two staircase of 1.05 m wide. Ground floor comprises upon 02 staff rooms and 07 class rooms. 1st floor comprises upon 02 computer lab, IT Section room and 08 class rooms. 2nd floor comprises upon 02 Science labs, Library room and 08 class rooms. As such no addition/ alteration should be made by the school management in the existing structure without prior information from this department. Any deviation found in this regard, this fire safety provisional certificate/guidelines issued will be treated automatically withdrawn/cancelled.
- 10 The students of preschool, kindergarten, up to class 1st shall be accommodated on ground floor and class 2nd students shall be accommodated not above 1st floor of the building.
- 11 This provisional fire safety clearance shall be subject to outcome of any dispute/investigation enquiry/trial if any pending before any court of Law/Investigation agency. This fire safety provisional certificate shall not confirm any title upon the person/company in whose favour it is issued.
- 12 This fire safety clearance certificate is issued in respect of the school with validity of six months and same needs to be renewed after checking fire fighting system installed in the building. However, before granting permission/recognition/extension or renewal thereof, the concerned authority shall satisfy himself in terms of conditions laid down in SRO-123 of 2010 & SRO -292 of 2018 issued by Education Department with regard to physical facilities & also ensure the fire safety measures/guidelines given to the proprietor by this department are fully complied with.


18/03/2024
Director,
Fire & Emergency Services, J&K,
Jammu/Srinagar